

Pre-Inspection Check List

Items that can be checked and should be up to date prior to fire marshal arrival include:

1. All extinguishing equipment has been inspected and has updated tags.
2. All fire alarm and sprinkler systems have been inspected and tested.
3. All emergency lighting and exit signage is in place and in working order.
4. Hoods over cooking equipment have been cleaned and tagged.
5. All egress passageways are free of obstructions.
6. All egress doors open freely and are not blocked.
7. All manual pull stations are free from obstruction and are visible.