

Dunn's Corners Fire District
Serving Westerly & Charlestown Since 1942

Updated: 3/29/2016

PLEASE REVIEW NEW UPDATES TO THE FIRE CODE

STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS
FIRE SAFETY CODE BOARD OF APPEAL AND REVIEW

FIRE CODE REQUIREMENTS FOR ONE AND TWO FAMILY HOME SMOKE AND CARBON
MONOXIDE INSPECTIONS

APPROVED: JANUARY 15, 2013

The following are the current fire code requirements for one and two family home smoke and carbon monoxide inspections under the newly adopted Fire Code:

Homes built in 1976 or prior:

Smoke Alarms shall be installed outside sleeping areas and on each level of the dwelling unit (s) (including basements).

Smoke Alarms shall be permitted to be battery operated.

Smoke Alarms are not required to be interconnected.

Carbon monoxide Detectors shall be installed outside sleeping areas.

Carbon monoxide Detectors shall be permitted to be battery operated.

Carbon monoxide Detectors are not required to be interconnected.

Homes built on and after January 1, 1977 through December 31, 2001:

Smoke alarms shall be installed outside sleeping areas and on each level of the dwelling unit (s) (including basements).

Smoke Alarms shall be hard-wired with battery backup.

Smoke Alarms shall be required to be interconnected.

Carbon monoxide Detectors shall be installed outside sleeping areas.

Carbon monoxide Detectors shall be permitted to be battery operated.

Carbon monoxide Detectors are not required to be interconnected.

*Dunn's Corners Fire District
Serving Westerly & Charlestown Since 1942*

Updated: 3/29/2016

Homes built on and after January 1, 2002 through February 19, 2004:

Smoke Alarms shall be installed outside sleeping areas and on each level of the dwelling unit (s) (including basements).

Smoke Alarms shall be hardwired with battery backup.

Smoke Alarms shall be required to be interconnected.

Carbon monoxide Detectors shall be installed outside sleeping areas.

Carbon monoxide Detectors shall be hard-wired with battery backup.

Carbon monoxide Detectors shall be required to be interconnected.

Homes built on and after February 20, 2004 through December 31, 2012:

Smoke Alarms shall be installed inside each bedroom, outside sleeping areas and on each level of the dwelling unit (s) (including basements) (In accordance with NFPA 72 2002 Edition)

Smoke Alarms shall be hard-wired with battery backup.

Smoke Alarms shall be required to be interconnected.

Carbon monoxide Detectors shall be installed outside each sleeping area and on each level of the dwelling unit including basements.

Carbon monoxide Detectors shall be hard-wired with battery backup.

Carbon monoxide Detectors shall be required to be interconnected.

Homes built on and after January 1, 2013:

Smoke Alarms shall be installed in accordance with NFPA 72 2010 Edition.

Carbon Monoxide Detectors shall be installed in accordance with NFPA 720 2012 Edition.

Where the above provisions require both smoke alarms and carbon monoxide detectors, combination devices shall be permitted and deemed to be acceptable.

Where smoke alarms are required, household fire alarm systems, in accordance with NFPA 72 2010 Edition, shall be permitted.

*Dunn's Corners Fire District
Serving Westerly & Charlestown Since 1942*

Updated: 3/29/2016

The local fire authority that performs smoke and carbon monoxide detector inspections in all residential occupancies shall, at the time of inspection, be allowed to charge a thirty dollar (\$30.00) fee for the inspection. A sixty dollar (\$60.00) fee will be allowed for any subsequent re-inspection of the same residential occupancy due to improper installation, wrong location, improper wiring method or the seller's failure to maintain a mutually agreed upon appointment with the local fire authority that performs the inspection function.

Please contact the Fire Marshal office at 401-322-0577 with any questions you may have.

For commercial and residential inspections or plan reviews, please call Station 1 at (401) 322-0577 and leave a message. In your message, please include:

- 1) Date and time of your call
- 2) Your name, address, and telephone number
- 3) Your message

Keep in mind:

- We are booked out a least a week in advance to your call, please plan ahead to get your inspection scheduled at least a week in advance of your closing.
- Monitored Alarm Systems, the company needs to be present during the inspection.
- House numbers shall be installed per Westerly & Charlestown Town ordinances
- Battery devices must to be mounted firmly in the appropriate locations.
- Plug-in C/O detectors are not acceptable.
- Detectors over 10 years old must be replaced
- Certificates are good for one hundred twenty day (120) from inspection date.

You may also drop off your plans at Station 1 to our Administrative Assistant on Monday, Tuesday, Wednesday or Friday between the hours of 9:00 AM and 3:30 PM. If you are dropping plans off, you must also fill-out the application for residential and commercial plan review. Found on our web site: <http://www.dunnscornersfire.com/content/inspections> See the guidelines and fee schedule for residential and commercial plan reviews.